AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client: Bautex Floors

129 Delta Street Geebung QLD 4034 **Test Number** : 19-000860

Issue Date : 10/05/2019
Print Date : 10/05/2019

Sample Description Clients Ref : "Boyer Easy Lay Planks"

Vinyl Planks

End Use: Flooring

Nominal Composition: PVC

Nominal Mass per Unit Area/Density:

Nominal Thickness: 5mm

Approx: 8.8kg/m2

AS/ISO 9239.1-2003

Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a

Radiant Heat Source

Date of Sample Arrival

Date Tested

15/02/2019 10/05/2019

CHF Value 1 Length 10.1

2

3

Mean - kW/m²

kW/m²

kW/m²

kW/m²

% min

HF-30 Value

Width

Length

Width

Length

Width

10.1

1

9.9

9.4

9.8 Mean

- - - -

123

138

Smoke Value 1

2

121

3

115

Mean - %.min

125

Yes

Page 1 of 2

Observations :

Transitory flaming Blistering

Yes

165315

Australian Wool testing Authority Ltd

Copyright - All Rights Reserved

34185

85

- Chemical Testing
- Mechanical Testing

: Accreditation No. : Accreditation No. 983

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA

Accredited for compliance with ISO/IEC 17025 - Testing

Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results

relate only to the sample or samples tested. This document shall not be reproduced except in full and shall

MICHAEL A. JACKSON B.Sc.(Hons)

0204/11/06

APPROVED SIGNATORY

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400 Fax (03) 9371 2499

TEST REPORT

Client: Bautex Floors

129 Delta Street Geebung QLD 4034 **Test Number** : 19-000860 **Issue Date** : 10/05/2019

Print Date : 10/05/2019

The test results relate to the behaviour of the test specimens of a product under the particular conditions of the test, they are not intended to be sole criterion for assessing the potential fire hazard of the product in use.

Sample was conditioned in accordance with BSEN 13238:2010 at a temperature of 23±2°C and relative humidity of 50±5% for a minimum of 48 hours prior to testing.

Each specimen was adhered to a substrate of 6mm thick fibre reinforced cement board using Roberts 656 adhesive and clamped prior to testing.

HF30 not reported as flame out time occurred before 30 minutes.

Results in accordance with section 8.4 have not been included in the report. They are available upon request.

165315 34185 Page 2 of 2

 Australian Wool testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing - Chemical Testing - Mechanical Testing

: Accreditation No. : Accreditation No.

983

AWTA LIMITED

Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results

Samples and their identifying descriptions have been provided by the client unless otherwise stated.

relate only to the sample or samples tested. This document shall not be reproduced except in full and shall

APPROVED SIGNATORY

MICHAEL A. JACKSON B.Sc.(Hons)